Features

- 1-channel isolated barrier
- 24 V DC supply (loop powered)
- · SMART fire alarm input
- Current input 1 mA ... 20 mA

Function

This isolated barrier is used for intrinsic safety applications. It provides control and signal transfer for SMART compatible fire and smoke alarm transmitters inside hazardous areas.


The typical application for the barrier is connection of a fire detector loop to a control panel through a System Sensor[®] translator device (typically an IST200).

The fall time of the digital signal must be less than 50 μ s, the current in the hazardous area must be bigger than 1 mA.

Since this isolator is loop-powered, use the technical data to verify that proper voltage is available to the field devices.

Assembly


Front view







Connection



General specifications		
Signal type		Analog input
Supply		
Rated voltage	U_r	loop powered
Power dissipation	-1	0.2 W
Control circuit		0.2 11
Connection		tarminala 11 L 12
		terminals 11+, 12-
Current		0 20 mA
Transmission range		current: 1 20 mA voltage: 0 24 V
Field circuit		
Connection		terminals 1+, 2-
Short-circuit current		≤ 65 mA
Transfer characteristics		
Deviation		
After calibration		≤ 3.5 mA current loss at 20 mA load current
Influence of ambient temperature		± 20 μA / K
Rise time/fall time		≤50 μs (load current ≥ 1 mA)
		≤ 50 μs (load current ≥ 1 mA)
Galvanic isolation		and a landwind in this case to IEO/EN 20070 44
Input/Output		safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V
Indicators/settings		
Labeling		space for labeling at the front
Directive conformity		
Electromagnetic compatibilit	ty	
Directive 2014/30/EU		EN 61326-1:2013 (industrial locations)
Conformity		
Electromagnetic compatibilit	tv	NE 21:2006
Degree of protection		IEC 60529:2001
Protection against electrical shock		UL 61010-1
	SHOCK	OL 61010-1
Ambient conditions		
Ambient temperature		-20 60 °C (-4 140 °F)
Mechanical specifications		
Degree of protection		IP20
Connection		screw terminals
Mass		approx. 100 g
Dimensions		20 x 107 x 115 mm (0.8 x 4.2 x 4.5 inch) , housing type B1
Mounting		on 35 mm DIN mounting rail acc. to EN 60715:2001
Data for application in corwith hazardous areas	nnection	
EU-Type Examination Certificate		BAS 00 ATEX 7087
Marking		(a) II (1)G [Ex ia Ga] IIC, (b) II (1)D [Ex ia Da] IIIC, (c) I (M1) [Ex ia Ma] I (-20 °C ≤ T_{amb} ≤ 60 °C)
*	11	
Voltage	U _o	25.2 V
Current	l _o	43 mA
Power	Po	271 mW
Supply		
Maximum safe voltage	U_m	250 V (Attention! The rated voltage can be lower.)
Type of protection [Ex ia]		
Certificate		TÜV 99 ATEX 1499 X
Marking		(Ex) II 3G Ex nA II T4 [device in zone 2]
Galvanic isolation		<u></u>
		safe electrical isolation acc. to IEC/EN 60079-11, voltage peak value 375 V
		Sale electrical isolation acc. to IEO/EN 000/9-11, voltage peak value 3/3 v
Input/Output		
Input/Output Directive conformity		EN 20070 2 2010 Att 2010 EN 20070 11 2010 EN 20070 15 2010
Input/Output Directive conformity Directive 2014/34/EU		EN 60079-0:2012+A11:2013 , EN 60079-11:2012 , EN 60079-15:2010
Input/Output Directive conformity Directive 2014/34/EU International approvals		EN 60079-0:2012+A11:2013 , EN 60079-11:2012 , EN 60079-15:2010
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval		
Input/Output Directive conformity Directive 2014/34/EU International approvals		EN 60079-0:2012+A11:2013 , EN 60079-11:2012 , EN 60079-15:2010 116-0129 (cFMus)
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval		
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval Control drawing UL approval		116-0129 (cFMus)
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval Control drawing UL approval Control drawing		116-0129 (cFMus) 116-0348 (cULus)
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval Control drawing UL approval Control drawing IECEx approval		116-0129 (cFMus) 116-0348 (cULus) IECEX BAS 08.0079 IECEX BAS 10.0007X
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval Control drawing UL approval Control drawing IECEx approval Approved for		116-0129 (cFMus) 116-0348 (cULus)
Input/Output Directive conformity Directive 2014/34/EU International approvals FM approval Control drawing UL approval Control drawing IECEx approval		116-0129 (cFMus) 116-0348 (cULus) IECEx BAS 08.0079 IECEx BAS 10.0007X [Ex ia Ga] IIC, [Ex ia Da] IIIC, [Ex ia Ma] I

